



Account Name:
 Asset Location (Service Address):

Engine	Generator
Caterpillar	
G3306TA	MagnaPlus
07Y08087	MX193767

Load Test Report

Work Order:

Engine Fluids:		Load Test Reports			Test Equipment	
Engine Fluids:		Serviceperson:	Test Date	<input type="text" value="26-Aug-16"/>	Make	<input type="text" value="Avtron"/>
<input type="text" value="Full"/>	Oil Level	<input type="text" value="Skish"/>	Time In	<input type="text"/>	Model	<input type="text"/>
<input type="text" value="Full"/>	Coolant Level		Time Out	<input type="text"/>	Serial #	<input type="text"/>
<input type="text" value="NA"/>	Starting Fuel Level		Total Time:	<input type="text" value="0:00"/>		
<input type="text" value="NA"/>	Ending Fuel Level					

Date	Time	Hour Meter	Volt Meter	Frequency (Hz)	Power (kW)	Leg A Amps	Leg B Amps	Leg C Amps	Oil Press (PSI)	Water Temp (F)	Ambient Temp (F)
26-Aug-16	12:30 PM	2,640.00	480.0	60	40	49	50	50	54	182	91
26-Aug-16	12:45 PM	2,640.00	480.0	60	72	88	87	87	53	183	91
26-Aug-16	1:00 PM	2,640.00	480.0	60	110	132	134	135	52	185	91
26-Aug-16	1:15 PM	2,640.00	480.0	60	149	180	180	182	52	185	91

Account Name:

4988

Asset Location (Service Address):

Sales

Work Order:

WO-0015602

Date:

26-Aug-16

